


Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Igralnica P-540m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 9,7 m
 width = 6,2 m
 floor = 60,1 m²
 volume = 180,4 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 9,20 m
 X3 = 1,35 m
 X4 = 1,35 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,5 l/s m² floor
 Required supply air flow rate in space : 150 l/s
 Air change coefficient : 3,0 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Calculation results for cooling :

Diffuser type : LD-13/2
 Diffuser air flow rate : Vol = 42,9 l/sm (154,3 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,44 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,33 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,136 dtL = -1,1 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,101 dtL = -0,8 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 5,4 Pa

Sound power level of the diffuser :

Lw63 = 31 dB Lw125 = 37 dB Lw250 = 37 dB Lw500 = 29 dB Lw1000 = 15 dB
 Lw2000 = 6 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 31,1 dB(A) NR = 28

Sound pressure level in space at 1,8 m :

Lp63 = 28 dB Lp125 = 33 dB Lp250 = 34 dB Lp500 = 25 dB Lp1000 = 11 dB
 Lp2000 = 0 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 27,3 dB(A) NR = 24

Diffuser :


Supply : Cooling (Coanda effect) - Two sided
 length = 3,5 m

Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Večnamenski prostor P-1176m3/h

Air diffusion :




Space :

height = 3,0 m
 length = 10,1 m
 width = 12,6 m
 floor = 127,3 m²
 volume = 381,8 m³

Placement :

dl = 0,00 m
 db = 2,20 m
 X1 = 0,50 m
 X2 = 9,60 m
 X3 = 1,86 m
 X4 = 1,86 m
 nl = 1
 nb = 2

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,6 l/s m² floor
 Required supply air flow rate in space : 326 l/s
 Air change coefficient : 3,1 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Two sided
 length = 3,5 m

Calculation results for cooling :

Diffuser type : LD-13/2
 Diffuser air flow rate : Vol = 46,6 l/sm (167,7 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,47 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,36 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,136 dtL = -1,1 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,101 dtL = -0,8 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 6,2 Pa



Sound power level of the diffuser :

Lw63 = 33 dB Lw125 = 38 dB Lw250 = 39 dB Lw500 = 31 dB Lw1000 = 18 dB
 Lw2000 = 9 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 33,1 dB(A) NR = 30

Sound pressure level in space at 1,8 m :

Lp63 = 29 dB Lp125 = 34 dB Lp250 = 36 dB Lp500 = 27 dB Lp1000 = 14 dB
 Lp2000 = 2 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 29,3 dB(A) NR = 26

Diagrami



Tehnični podatki


	Zahtevana točka	Delovna točka			
	Pretok zraka [m ³ /h]	Q [m ³ /h]	Ps [Pa]	Lp [dB]	L (0,2 m/s) [(0.2 m/s) m]
Uporabnik	400	400	7,76	27,1	1,68

Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Dodatne dejavnosti P-250m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 4,0 m
 width = 6,2 m
 floor = 24,8 m²
 volume = 74,4 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 3,50 m
 X3 = 2,10 m
 X4 = 2,10 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,8 l/s m² floor
 Required supply air flow rate in space : 70 l/s
 Air change coefficient : 3,4 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Alternate sided
 length = 2,0 m

Calculation results for cooling :

Diffuser type : LD-13/1
 Diffuser air flow rate : Vol = 34,7 l/sm (125,1 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,33 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,24 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,069 dtL = -0,5 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,050 dtL = -0,4 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 17,2 Pa

Sound power level of the diffuser :

Lw63 = 44 dB Lw125 = 42 dB Lw250 = 42 dB Lw500 = 33 dB Lw1000 = 20 dB
 Lw2000 = 14 dB Lw4000 = 4 dB Lw8000 = 0 dB LwA = 35,7 dB(A) NR = 33

Sound pressure level in space at 1,8 m :


Lp63 = 43 dB Lp125 = 41 dB Lp250 = 41 dB Lp500 = 32 dB Lp1000 = 20 dB
 Lp2000 = 13 dB Lp4000 = 1 dB Lp8000 = 0 dB LpA = 34,8 dB(A) NR = 32

Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Pisarne P-40m3/h

Air diffusion :




Space :

height = 3,0 m
 length = 4,0 m
 width = 3,0 m
 floor = 12,2 m²
 volume = 36,6 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 3,50 m
 X3 = 1,25 m
 X4 = 1,25 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 0,9 l/s m² floor
 Required supply air flow rate in space : 11 l/s
 Air change coefficient : 1,1 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - One sided
 length = 0,5 m

Calculation results for cooling :

Diffuser type : LD-13/1
 Diffuser air flow rate : Vol = 22,0 l/sm (79,1 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,45 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,34 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,136 dtL = -1,1 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,101 dtL = -0,8 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 4,3 Pa

Sound power level of the diffuser :

Lw63 = 24 dB Lw125 = 18 dB Lw250 = 18 dB Lw500 = 7 dB Lw1000 = 0 dB
 Lw2000 = 0 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 12,7 dB(A) NR = 8

Sound pressure level in space at 1,8 m :


Lp63 = 23 dB Lp125 = 17 dB Lp250 = 17 dB Lp500 = 6 dB Lp1000 = 0 dB
 Lp2000 = 0 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 11,1 dB(A) NR = 8

Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Pralnica P-320m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 5,2 m
 width = 6,2 m
 floor = 32,2 m²
 volume = 96,7 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 4,70 m
 X3 = 2,10 m
 X4 = 2,10 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,8 l/s m² floor
 Required supply air flow rate in space : 89 l/s
 Air change coefficient : 3,3 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Alternate sided
 length = 2,0 m

Calculation results for cooling :

Diffuser type : LD-13/2
 Diffuser air flow rate : Vol = 44,4 l/sm (160,0 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,30 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,22 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,096 dtL = -0,8 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,071 dtL = -0,6 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 5,7 Pa

Sound power level of the diffuser :

Lw63 = 32 dB Lw125 = 38 dB Lw250 = 38 dB Lw500 = 30 dB Lw1000 = 16 dB
 Lw2000 = 7 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 31,9 dB(A) NR = 29

Sound pressure level in space at 1,8 m :


Lp63 = 30 dB Lp125 = 36 dB Lp250 = 36 dB Lp500 = 28 dB Lp1000 = 14 dB
 Lp2000 = 6 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 30,1 dB(A) NR = 27

Air distribution design

Project data :

Name of the project : Vrtec Kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Igralnica 1N-630m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 9,9 m
 width = 6,3 m
 floor = 62,2 m²
 volume = 186,7 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 9,40 m
 X3 = 1,10 m
 X4 = 1,19 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,8 l/s m² floor
 Required supply air flow rate in space : 175 l/s
 Air change coefficient : 3,4 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Two sided
 length = 4,0 m

Calculation results for cooling :

Diffuser type : LD-13/2
 Diffuser air flow rate : Vol = 43,8 l/sm (157,5 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,44 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,34 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,136 dtL = -1,1 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,101 dtL = -0,8 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 5,6 Pa

Sound power level of the diffuser :

Lw63 = 32 dB Lw125 = 37 dB Lw250 = 38 dB Lw500 = 29 dB Lw1000 = 15 dB
 Lw2000 = 7 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 31,5 dB(A) NR = 28

Sound pressure level in space at 1,8 m :


Lp63 = 28 dB Lp125 = 33 dB Lp250 = 34 dB Lp500 = 25 dB Lp1000 = 12 dB
 Lp2000 = 1 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 27,6 dB(A) NR = 24

Air distribution design

Project data :

Name of the project : kamnitnik
 Customer :
 Reference :
 Designed by : Zupan
 Information : Zbornica 840m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 12,5 m
 width = 6,0 m
 floor = 75,0 m²
 volume = 225,0 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 12,00 m
 X3 = 1,00 m
 X4 = 1,00 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 3,1 l/s m² floor
 Required supply air flow rate in space : 233 l/s
 Air change coefficient : 3,7 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Alternate sided
 length = 4,0 m

Calculation results for cooling :

Diffuser type : LD-13/3
 Diffuser air flow rate : Vol = 58,3 l/sm (210,0 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,33 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,24 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,121 dtL = -1,0 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,087 dtL = -0,7 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 2,4 Pa

Sound power level of the diffuser :

Lw63 = 43 dB Lw125 = 28 dB Lw250 = 37 dB Lw500 = 27 dB Lw1000 = 13 dB
 Lw2000 = 7 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 30,4 dB(A) NR = 28

Sound pressure level in space at 1,8 m :


Lp63 = 38 dB Lp125 = 24 dB Lp250 = 33 dB Lp500 = 23 dB Lp1000 = 9 dB
 Lp2000 = 1 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 26,0 dB(A) NR = 23

Air distribution design

Project data :

Name of the project :
 Customer :
 Reference :
 Designed by : Zupan
 Information : Zbornica-N_840m3/h

Air diffusion :




Space :

height = 3,0 m
 length = 5,2 m
 width = 12,4 m
 floor = 64,5 m²
 volume = 193,4 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 4,70 m
 X3 = 4,20 m
 X4 = 4,20 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 1,6 l/s m² floor
 Required supply air flow rate in space : 106 l/s
 Air change coefficient : 2,0 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Alternate sided
 length = 4,0 m

Calculation results for cooling :

Diffuser type : LD-13/1
 Diffuser air flow rate : Vol = 26,4 l/sm (95,0 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,25 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,19 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,069 dtL = -0,5 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,050 dtL = -0,4 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 9,8 Pa

Sound power level of the diffuser :

Lw63 = 37 dB Lw125 = 35 dB Lw250 = 33 dB Lw500 = 22 dB Lw1000 = 7 dB
 Lw2000 = 0 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 26,4 dB(A) NR = 23

Sound pressure level in space at 1,8 m :


Lp63 = 33 dB Lp125 = 31 dB Lp250 = 29 dB Lp500 = 18 dB Lp1000 = 2 dB
 Lp2000 = 0 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 22,3 dB(A) NR = 18

Air distribution design

Project data :

Name of the project :
 Customer :
 Reference :
 Designed by : Zupan
 Information : Pisanne-N_60m3/h

Air diffusion :




Space :

height = 3,0 m
 length = 4,6 m
 width = 3,0 m
 floor = 13,8 m²
 volume = 41,4 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 4,10 m
 X3 = 1,25 m
 X4 = 1,25 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 1,2 l/s m² floor
 Required supply air flow rate in space : 17 l/s
 Air change coefficient : 1,4 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Alternate sided
 length = 0,5 m

Calculation results for cooling :

Diffuser type : LD-13/1
 Diffuser air flow rate : Vol = 33,3 l/sm (120,0 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,32 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,23 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,069 dtL = -0,5 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,050 dtL = -0,4 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 9,0 Pa

Sound power level of the diffuser :

Lw63 = 27 dB Lw125 = 24 dB Lw250 = 26 dB Lw500 = 17 dB Lw1000 = 1 dB
 Lw2000 = 0 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 19,3 dB(A) NR = 15

Sound pressure level in space at 1,8 m :


Lp63 = 25 dB Lp125 = 22 dB Lp250 = 24 dB Lp500 = 15 dB Lp1000 = 0 dB
 Lp2000 = 0 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 17,6 dB(A) NR = 14

Air distribution design

Project data :

Name of the project :
 Customer :
 Reference :
 Designed by : Zupan
 Information : Dodatne-dejavnosti-N_350m3/h

Air diffusion :




Space :

height = 3,0 m
 length = 6,0 m
 width = 6,1 m
 floor = 36,6 m²
 volume = 109,8 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 0,50 m
 X2 = 5,50 m
 X3 = 2,05 m
 X4 = 2,05 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 2,7 l/s m² floor
 Required supply air flow rate in space : 99 l/s
 Air change coefficient : 3,2 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Two sided
 length = 2,0 m

Calculation results for cooling :

Diffuser type : LD-13/2
 Diffuser air flow rate : Vol = 49,4 l/sm (177,9 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=1,7m) : vL = 0,49 m/s
 Mean air velocity by the wall at the floor level (L=3,5m) : vL = 0,38 m/s
 Temperature quotient at the distance L=X1+H1 (L=1,7m) : dtL/dtz = 0,136 dtL = -1,1 K
 Temperature quotient at the distance L=X1+H (L=3,5m) : dtL/dtz = 0,101 dtL = -0,8 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 6,9 Pa

Sound power level of the diffuser :

Lw63 = 34 dB Lw125 = 39 dB Lw250 = 41 dB Lw500 = 33 dB Lw1000 = 20 dB
 Lw2000 = 11 dB Lw4000 = 0 dB Lw8000 = 0 dB LwA = 34,7 dB(A) NR = 32

Sound pressure level in space at 1,8 m :


Lp63 = 32 dB Lp125 = 37 dB Lp250 = 39 dB Lp500 = 30 dB Lp1000 = 18 dB
 Lp2000 = 9 dB Lp4000 = 0 dB Lp8000 = 0 dB LpA = 32,4 dB(A) NR = 29

Air distribution design

Project data :

Name of the project :
 Customer :
 Reference :
 Designed by : Zupan
 Information : Hodnik-N_480m³/h

Air diffusion :




Space :

height = 3,0 m
 length = 2,0 m
 width = 10,0 m
 floor = 20,0 m²
 volume = 60,0 m³

Placement :

dl = 0,00 m
 db = 0,00 m
 X1 = 1,00 m
 X2 = 1,00 m
 X3 = 4,50 m
 X4 = 4,50 m
 nl = 1
 nb = 1

Placement of diffusers :



Definitions :

Vol [l/sm] : Air flow rate at the diffuser per meter
 dl,db [m] : Distance between the diffusers
 X1,X2,X3,X4 [m] : Distance between the diffuser and the wall
 H1 [m] : Distance between the diffuser and the stand level
 H [m] : Installation height of the diffuser
 h1 [m] : Vertical throw of the diffuser for heating
 h1max [m] : Maximum throw of the diffuser for heating
 vH1 [m/s] : Air velocity between the diffusers at the distance H1
 vL [m/s] : Air velocity by the wall at the distance L
 LwA [dB(A)] : A-weighted sound power level
 LpA [dB(A)] : A-weighted sound pressure level in room
 dpt [Pa] : Pressure drop at the diffuser

Placement :

dl [m] : Distance along long side of the space
 db [m] : Distance along broad side of the space
 X1 [m] : Distance from the left wall
 X2 [m] : Distance from the right wall
 X3 [m] : Distance from the lower wall
 X4 [m] : Distance from the upper wall
 nl [] : Number of diffusers along long side of the space
 nb [] : Number of diffusers along broad side of the space

Design criteria :

Optimal operative temperature : 26,0 °C
 Supply air temperature : 18,0 °C
 Temperature difference : -8,0 K
 Permissible mean air velocity in occupied zone : 0,15 m/s
 Required supply air flow rate : 6,7 l/s m² floor
 Required supply air flow rate in space : 134 l/s
 Air change coefficient : 8,0 1/h
 Sound pressure level : 35 dB(A)
 Sound increment : 0 dB
 Reverberation time : 1,0 s
 Occupied zone : 1,8 m

Diffuser :

Supply : Cooling (Coanda effect) - Two sided
 length = 1,0 m

Calculation results for cooling :

Diffuser type : LD-13/4
 Diffuser air flow rate : Vol = 134,0 l/sm (482,4 m³/hm)
 Mean air velocity by the wall at the occupied zone level (L=2,2m) : vL = 0,79 m/s
 Mean air velocity by the wall at the floor level (L=4,0m) : vL = 0,61 m/s
 Temperature quotient at the distance L=X2+H1 (L=2,2m) : dtL/dtz = 0,174 dtL = -1,4 K
 Temperature quotient at the distance L=X2+H (L=4,0m) : dtL/dtz = 0,130 dtL = -1,0 K
 Pressure drop on the diffuser (regulation=100%) : dpt = 13,8 Pa

Sound power level of the diffuser :

Lw63 = 36 dB Lw125 = 36 dB Lw250 = 41 dB Lw500 = 30 dB Lw1000 = 23 dB
 Lw2000 = 15 dB Lw4000 = 4 dB Lw8000 = 0 dB LwA = 34,1 dB(A) NR = 32

Sound pressure level in space at 1,8 m :

Lp63 = 33 dB Lp125 = 33 dB Lp250 = 38 dB Lp500 = 27 dB Lp1000 = 21 dB
 Lp2000 = 13 dB Lp4000 = 1 dB Lp8000 = 0 dB LpA = 31,3 dB(A) NR = 29